



PUBLIC HEALTH ENGINEERING DEPARTMENT
STATE WATER TESTING LABORATORY, KARNAL-132001
E-mail:-chemist.karnal@phedharyana.gov.in, chemistkarnal@gmail.com



Test Report No. : 1901/10/19	Issue Date: Memo No.: 867 Date:- 18/10/19
Issued to: Principal Rising Sun Public Sch. Kalyan Farm G.T. Road Madhuban, Karnal.	Location : U/S (R.O. Treated) at Sch. Campus.
Sample Type : Chemical Test	Sample collected Date & Time: 17/10/19
	Sample received Date & Time: 17/10/19

Test Result


S.No.	Tested Parameter	Result	Unit	Acceptable	Permissible Limit (As per IS 10500:2012)
1	Turbidity	Nil	NTU	1	5
2	Odor	Normal	---	Unobjectionable	---
3	Total Dissolve Solids	150	mg/l	500 mg/l	2000 mg/l
4	Total Hardness as CaCO ₃	100	mg/l	200 mg/l	600 mg/l
5	Calcium as Ca	20	mg/l	75 mg/l	200 mg/l
6	Magnesium as Mg	12	mg/l	30 mg/l	100 mg/l
7	Chloride as Cl	20	mg/l	250 mg/l	1000 mg/l
8	Total Alkalinity	90	mg/l	200 mg/l	600 mg/l
9	Fluoride as F	0.210	mg/l	1.0 mg/l	1.5 mg/l
10	Iron as Fe	Nil	mg/l	1.0 mg/l	No Relaxation
11	Nitrate as No ₃	1.0	mg/l	45 mg/l	No Relaxation
12	Sulphate as So ₄	10	mg/l	200 mg/l	400 mg/l
13	pH	7.25	---	6.5-8.5	No Relaxation
14	Free Residual Chlorine	-	mg/l	0.2	1.0

The above water sample conforms to relevant code for above tested parameters

Remarks:-

- The results given above are related to the sample as received and tested in PHED State Lab Karnal.
- The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED State Lab Karnal.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample lies with sender/collector of water sample.

Jaginder Singh,
Checked by


CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
STATE WATER TESTING LABORATORY
State Water Testing Lab, Karnal

---End of Report---